



中国认可  
国际互认  
检测  
TESTING  
CNAS L14701


# TEST REPORT

**Applicant:** Shenzhen LEMAX New Energy Co., Ltd

**Address:** A301, Building #A, Jian Creative Center, No. 54 Jizheng Road, Longgang District, Shenzhen, China

**Equipment Type:** Grid-connected PV Inverter

**Model Name:** SUN-60K-G03, SUN-50K-G03, SUN-40K-G03, SUN-35K-G03, SUN-33K-G03, SUN-30K-G03

**Brand Name:**  LEMAX

**Ratings:** See copy of marking label and model list.

**Test Standard:** IEC 62109-2:2011, EN 62109-2:2011

**Test Date:** Aug. 02, 2022 to Oct. 14, 2022

**Date of Issue:** Jan. 30, 2023

## ISSUED BY:

Dongguan BALUN Testing Technology Co., Ltd.

**Tested by:** Leo Sun

**Leo Sun**

**Checked by:** Xingzhen Man

**Xingzhen Man**

**Approved by:** Simon Qi

**Simon Qi**



### Revision History

Version	Issue Date	Revisions Content
<u>Rev. 01</u>	<u>Jan. 30, 2023</u>	<u>Initial Issue</u>

#### List of Attachments:

None.

#### Summary of testing:

-Note: The only difference between the EUT (test samples in this report) and testing sample of report BL-DG2280869-B01 A1, which was issued by Dongguan BALUN Testing Technology Co., Ltd. on Dec. 01, 2022 as below:

1. Update applicant, manufacturer, trademark, label and appearance.

And others hardware circuit and software were all the same. So all test data originate from the report BL-DG2280869-B01 A1, which was issued by Dongguan BALUN Testing Technology Co., Ltd. on Dec. 01, 2022.

#### Tests performed (name of test and test clause):

- ☒ 4.4.4.15.1 Fault-tolerance of residual current monitoring
- ☒ 4.4.4.15.2 Fault-tolerance of automatic disconnecting means
- ☒ 4.4.4.17 Cooling system failure – Blanketing test
- ☒ 4.8.2 Array insulation resistance detection for inverters for ungrounded and functionally grounded arrays
- ☒ 4.8.3 Array residual current detection
- ☒ 4.8.3.5 Protection by residual current monitoring

- Other testing conditions considered in this test report, see General product information of the report BL-DG2310512-B01 for details.

#### Testing location:

The tests of clause 4.8.3.5.2, 4.8.3.5.3 are performed listed Dongguan BALUN Testing Technology Co., Ltd. Room 104, 204, 205, Building 1, No. 6, Industrial South Road, Songshan Lake District, Dongguan, Guangdong, China.

☒ **List of countries addressed: See report BL-DG2310512-B01.**

**Copy of marking plate:**

See report BL-DG2310512-B01

<b>Test item particulars..... :</b>	
<b>Equipment mobility..... :</b>	Permanent connection
<b>Operating condition..... :</b>	Continuous
<b>Enviromental category..... :</b>	Outdoor use
<b>Over voltage category Mains..... :</b>	OVC III
<b>Over voltage category PV..... :</b>	OVC II
<b>Class of equipment..... :</b>	Class I
<b>Pollution degree..... :</b>	PD3(Inside PD2)
<b>IP protection class..... :</b>	IP65
<b>Mass of equipment (kg)..... :</b>	20
<b>Possible test case verdicts:</b>	
- test case does not apply to the test object..... :	N/A
- test object does meet the requirement..... :	P (Pass)
- test object was not evaluated for the requirement:	N/E
- test object does not meet the requirement..... :	F (Fail)

**General remarks:**

"(See Enclosure #)" refers to additional information appended to the report.

"(See appended table)" refers to a table appended to the report.

Throughout this report a ☐ comma / ☒ point is used as the decimal separator.

**Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60335-1:**

The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided.....:

- ☐ Yes  
☒ Not applicable

**When differences exist; they shall be identified in the General product information section.**

**Name and address of Manufacturer (ies).....:** See report BL-DG2310512-B01.

**Name and address of factory (ies).....:** See report BL-DG2310512-B01.

**General product information:**

See report BL-DG2310512-B01.

**Throughout the test report following abbreviations may be used:**

- |       |                             |       |                          |
|-------|-----------------------------|-------|--------------------------|
| ● cl  | clearance                   | ● int | internal distance        |
| ● dcr | creepage distance           | ● o-c | open-circuit             |
| ● dti | distance through insulation | ● o-l | overload                 |
| ● PCE | Power Conversion Equipment  | ● s-c | short-circuit            |
| ● BI  | basic insulation            | ● SI  | supplementary insulation |
| ● DI  | double insulation           | ● RI  | reinforced insulation    |

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
<b>4</b>	<b>GENERAL TESTING REQUIREMENTS</b>		-
4.4.4	Single fault conditions to be applied		P
4.4.4.15	Fault-tolerance of protection for grid-interactive inverters	The PCE could detect and indicate the fault condition and disconnect from or not connect to the grid in case of single fault condition. Refer to the appended table 4.4 of IEC/EN 62109-1 test report BL-DG2310512-B01.	-
4.4.4.15.1	Fault-tolerance of residual current monitoring according to 4.8.3.5: the residual current monitoring system operates properly	See appended table 4.4.4.15.1	P
	a).. - The inverter ceases to operate		P
	- Indicates a fault in accordance with §13.9		P
	- Disconnect from the mains		P
	- not re-connect after any sequence of removing and reconnecting PV power		P
	- not re-connect after any sequence of removing and reconnecting AC power		P
	- not re-connect after any sequence of removing and reconnecting both PV and AC power		P
	b).. - The inverter continues to operate		N/A
	- the residual current monitoring system operates properly under single fault condition		N/A
	- Indicates a fault in accordance with §13.9		N/A
	c).. - The inverter continues to operate regardless of loss of residual current monitoring functionality		N/A
	- not re-connect after any sequence of removing and reconnecting PV power		N/A
	- not re-connect after any sequence of removing and reconnecting AC power		N/A
	- not re-connect after any sequence of removing and reconnecting both PV and AC power		N/A
	- Indicates a fault in accordance with §13.9		N/A
4.4.4.15.2	Fault-tolerance of automatic disconnecting means		-
4.4.4.15.2.1	The means provided for automatic disconnection of a grid-interactive inverter from the mains shall:		-
	- disconnect all grounded current-carrying conductors from the mains	No grounded current-carrying conductors	N/A

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
	- disconnect all ungrounded current-carrying conductors from the mains		P
	- be such that with a single fault applied to the disconnection means or to any other location in the inverter, at least basic insulation or simple separation is maintained between the PV array and the mains when the disconnecting means is intended to be in the open state.	See appended table 4.4.4.15.2 Fault-tolerance of automatic disconnecting	P
4.4.4.15.2.2	Design of insulation or separation complies with requirements of 7.3.7 of Part 1: report here Part 1 comment and verdict.	The automatic disconnection means is automatically checked before the inverter start operation	P
4.4.4.15.2.3	For non-isolated inverter, automatic checking of the isolation provided by a disconnect means after single fault.	See appended test table 4.4.4.15.2 Fault-tolerance of automatic disconnecting.	P
	If the check fail: - any still-functional disconnection means shall be left in the open position		P
	- at least basic or simple separation shall be maintained between the PV input and the mains		P
	- the inverter shall not start operation		P
	- the inverter shall indicate a fault in accordance with 13.9		P
4.4.4.16	A stand-alone inverter with a transfer switch to transfer AC loads from the mains or other AC bypass source to the inverter output:	Not stand-alone inverter	N/A
	- shall continue to operate normally		N/A
	- shall not present a risk of fire as the result of an out-of-phase transfer		N/A
	- shall not present a risk of shock as the result of an out-of-phase transfer		N/A
	- And having control preventing switching: components for malfunctioning .....:		N/A
4.4.4.17	Cooling system failure – Blanketing test No hazards according to the criteria of sub-clause 4.4.3 of Part 1 shall result from blanketing the inverter This test is not required for inverters restricted to use only in closed electrical operating areas.	See appended test table Cooling system failure – Blanketing test.	P
	Test stop condition: time duration value or stabilized		-

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
	temperature .....		
4.7	ELECTRICAL RATINGS TESTS		-
4.7.4	Stand-alone Inverter AC output voltage and frequency		N/A
4.7.4.1	General	N/A	N/A
4.7.4.2	Steady state output voltage at nominal DC input The steady-state AC output voltage shall not be less than 90 % or more than 110 % of the rated nominal voltage with the inverter supplied with its nominal value of DC input voltage.	Not stand-alone inverter	N/A
4.7.4.3	Steady state output voltage across the DC input range The steady-state AC output voltage shall not be less than 85 % or more than 110 % of the rated nominal voltage with the inverter supplied with any value within the rated range of DC input voltage.		N/A
4.7.4.4	Load step response of the output voltage at nominal DC input The AC output voltage shall not be less than 85 % or more than 110 % of the rated nominal voltage for more than 1,5 s after application or removal of a resistive load.		N/A
4.7.4.5	Steady state output frequency The steady-state AC output frequency shall not vary from the nominal value by more than +4 % or –6 %.		N/A
4.7.5	Stand-alone inverter output voltage waveform		-
4.7.5.1	General		-
4.7.5.2	The AC output voltage waveform of a sinusoidal output stand-alone inverter shall have a total harmonic distortion (THD) not exceeding of 10 % and no individual harmonic at a level exceeding 6 %.	Not stand-alone inverter	N/A
4.7.5.3	Non-sinusoidal output waveform requirements		-
4.7.5.3.1	General		-
4.7.5.3.2	The total harmonic distortion (THD) of the voltage waveform shall not exceed 40 %.	Sinusoidal output wave form	N/A
4.7.5.3.3	The slope of the rising and falling edges of the positive and negative half-cycles of the voltage waveform shall not exceed 10 V/ $\mu$ s measured between the points at which the waveform has a voltage of 10 % and 90 % of the peak voltage for that half-cycle.		N/A
4.7.5.3.4	The absolute value of the peak voltage of the positive and negative half-cycles of the waveform shall not exceed 1,414 times 110 % of the RMS value of the rated		N/A



IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
	nominal AC output voltage.		
4.7.5.4	Information requirements for non-sinusoidal waveforms The instructions provided with a stand-alone inverter not complying with 4.7.5.2 shall include the information in 5.3.2.6.		N/A
4.7.5.5	Output voltage waveform requirements for inverters for dedicated loads. For an inverter that is intended only for use with a known dedicated load, the following requirements may be used as an alternative to the waveform requirements in 4.7.5.2 to 4.7.5.3.		N/A
	The combination of the inverter and dedicated load shall be evaluated to ensure that the output waveform does not cause any hazards in the load equipment and inverter, or cause the load equipment to fail to comply with the applicable product safety standards.	See attached document: 4.7.5.5 Evaluation of inverter for dedicated load	N/A
	The inverter shall be marked with symbols 9 and 15 of Table C.1 of Part 1.		N/A
	The installation instructions provided with the inverter shall include the information in 5.3.2.13.		N/A
4.8	ADDITIONAL TESTS FOR GRID-INTERACTIVE INVERTERS		-
4.8.1	General requirements regarding inverter isolation and array grounding	Non-isolation inverter	-
	- Type of Array grounding supported .....		N/A
	- Inverter isolation .....		N/A
4.8.2	Array insulation resistance detection for inverters for ungrounded and functionally grounded arrays	(See attached table)	P
4.8.2.1	Array insulation resistance detection for inverters for ungrounded arrays		P
	Inverter shall have means to measure DC insulation resistance from PV input (array) to ground before starting operation		P
	Or Inverter shall be provided with instruction in accordance with 5.3.2.11.	The inverter can measure DC insulation resistance from PV input array to ground before starting operation	N/A
	Measured DC insulation resistance: .....		P
	Inverter measurement circuit shall be capable of detecting insulation resistance below the limit value $R = V_{max}/30mA$ under normal conditions	The manufactory set the value is 33.3k ohm for PV+ to Ground, and 33.3k ohm for PV- to Ground	P

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
	Inverter measurement circuit shall be capable of detecting insulation resistance below the limit value $R = V_{max}/30mA$ with ground fault in the PV array	The manufactory set the value is 33.3k ohm for PV+ to Ground, and 33.3k ohm for PV- to Ground	P
	Isolated inverters shall indicate a fault if the insulation resistance is less than the limit value		P
	Isolated inverter fault indication maintained until insulation resistance has recovered to a value higher than the limit value		P
	Non-isolated inverters, or inverters with isolation not complying with the leakage current limits in the minimum inverter isolation requirements in Table 30:		N/A
	- shall indicate a fault in accordance with 13.9		N/A
	- shall not connect to the mains		N/A
4.8.2.2	Array insulation resistance detection for inverters for functionally grounded arrays		-
	a-1) The value of the total resistance, including the intentional resistance for array functional grounding, the expected insulation resistance of the array to ground, and the resistance of any other networks connected to ground (for example measurement networks) must not be lower than $R = (V_{MAX} PV/30 mA)$ ohms.	Not for functionally grounded arrays	N/A
	a-2) The installation instructions shall include the information required in 5.3.2.12.		N/A
	b-1) As an alternative to a), or if a resistor value lower than in a) is used, the inverter shall incorporate means to detect, during operation, if the total current through the resistor and any networks (for example measurement networks) in parallel with it, exceeds the residual current values and times in Table 31		N/A
	b-2) Inverter shall either disconnect the resistor or limit the current by other means .....		N/A
	b-3) If the inverter is a non-isolated inverter, or has isolation not complying with the leakage current limits in the minimum inverter isolation requirements in Table 30, it shall also disconnect from the mains.		N/A
	c) The inverter shall have means to measure the DC insulation resistance from the PV input to ground before starting operation, in accordance with 4.8.2.1.		N/A
4.8.3	Array residual current detection		P
4.8.3.1	General		-

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
4.8.3.2	30 mA touch current type test for isolated inverters		N/A
4.8.3.3	Fire hazard residual current type test for isolated inverters		N/A
4.8.3.4	Protection by application of RCD's		P
	- The requirement for additional protection in 4.8.3.1 can be met by provision of an RCD with a residual current setting of 30 mA, located between the inverter and the mains.		P
	- The selection of the RCD type to ensure compatibility with the inverter must be made according to rules for RCD selection in Part 1.		P
	- The RCD provided integral to the inverter, or		P
	- The RCD provided by the installer if details of the rating, type, and location for the RCD are given in the installation instructions per 5.3.2.9.		N/A
4.8.3.5	Protection by residual current monitoring		P
4.8.3.5.1	General		-
	Where required by Table 30, the inverter shall provide residual current monitoring that functions whenever the inverter is connected to the mains with the automatic disconnection means closed.		P
	The residual current monitoring means shall measure the total (both a.c. and d.c. components) RMS current.		P
	As indicated in Table 30 for different inverter types, array types, and inverter isolation levels, detection may be required for excessive continuous residual current, excessive sudden changes in residual current, or both, according to the following limits:		P
	a) Continuous residual current: The inverter shall disconnect within 0,3 s and indicate a fault in accordance with 13.9 if the continuous residual current exceeds:		P
	- maximum 300 mA for inverters with continuous output power rating $\leq 30$ kV;		P
	- maximum 10 mA per kVA of rated continuous output power for inverters with continuous output power rating > 30 kVA.		N/A
	The inverter may attempt to re-connect if the array insulation resistance meets the limit in 4.8.2.	Cannot re-connected	N/A
	b) Sudden changes in residual current: The inverter shall disconnect from the mains within the time specified in Table 31		P

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
	The inverter indicates a fault in accordance with 13.9, if a sudden increase in the RMS residual current is detected exceeding the value in the table.		P
	The inverter may attempt to re-connect if the array insulation resistance meets the limit in 4.8.2.	Cannot re-connected	N/A
4.8.3.5.2	Test for detection of excessive continuous residual current: test repeated 5 times and time to disconnect shall not exceed 0,3 s.	See appended test table 4.8.3.5.2 Test for detection of excessive continuous residual current	P
4.8.3.5.3	Test for detection of sudden changes in residual current repeated 5 times and each of the 5 results shall not exceed the time limit indicated in for each row (30mA, 60mA and 150mA) of Table 31.		P
4.8.3.6	Systems located in closed electrical operating areas	Not located in such areas	N/A
	The protection against shock hazard is not required if the installation information provided with the inverter indicates the restriction for use in a closed electrical operating area, and		N/A
	Installation information indicates what forms of shock hazard protection are and are not provided integral to the inverter, in accordance with 5.3.2.7.		N/A
	The inverter shall be marked as in 5.2.2.6.		N/A
<b>5</b>	<b>MARKING AND DOCUMENTATION</b>		-
5.1	Marking		-
5.1.4	Equipment ratings		-
	PV input ratings:		P
	- V <sub>max</sub> PV (absolute maximum) (d.c. V)		P
	- I <sub>sc</sub> PV (absolute maximum) (d.c. A)		P
	a.c. output ratings:		P
	- Voltage (nominal or range) (a.c. V)		P
	- Current (maximum continuous) (a.c. A)		P
	- Frequency (nominal or range) (Hz)		P
	- Power (maximum continuous) (W or VA)		P
	- Power factor range		P
	a.c. input ratings:		N/A
	- Voltage (nominal or range) (a.c. V)		N/A
	- Current (maximum continuous) (a.c. A)		N/A
	- Frequency (nominal or range) (Hz)		N/A
	d.c. output ratings:		N/A

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
	- Voltage (nominal or range) (d.c. V)		N/A
	- Current (maximum continuous) (d.c. A)		N/A
	Protective class (I or II or III)		P
	Ingress protection (IP) rating per part 1		P
	An inverter that is adjustable for more than one nominal output voltage shall be marked to indicate the particular voltage for which it is set when shipped from the factory.		P
5.2	Warning markings		-
5.2.2	Content for warning markings		-
5.2.2.6	Inverters for closed electrical operating areas		N/A
	Where required by 4.8.3.6, an inverter not provided with full protection against shock hazard on the PV array shall be marked with a warning that the inverter is only for use in a closed electrical operating area, and referring to the installation instructions.	Not for such areas	N/A
5.3	Documentation		-
5.3.2	Information related to installation		-
5.3.2.1	Ratings. Subclause 5.3.2 of Part 1 requires the documentation to include ratings information for each input and output. For inverters this information shall be as in Table 33 below. Only those ratings that are applicable based on the type of inverter are required.		-
	PV input quantities :		P
	- Vmax PV (absolute maximum) (d.c. V)		P
	- PV input operating voltage range (d.c. V)		P
	- Maximum operating PV input current (d.c. A)		P
	- Isc PV (absolute maximum) (d.c. A)		P
	- Isc PV (absolute maximum) (d.c. A)		P
	- Max. inverter backfeed current to the array (a.c. or d.c. A)		P
	a.c. output quantities:		P
	- Voltage (nominal or range) (a.c. V)		P
	- Current (maximum continuous) (a.c. A)		P
	- Current (inrush) (a.c. A, peak and duration)		P
	- Frequency (nominal or range) (Hz)		P
	- Power (maximum continuous) (W or VA)		P
	- Power factor range		P
	- Maximum output fault current (a.c. A, peak and duration or RMS)		P
	- Maximum output overcurrent protection (a.c. A)		P

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
	a.c. input quantities:		N/A
	- Voltage (nominal or range) (a.c. V)		N/A
	- Current (maximum continuous) (a.c. A)		N/A
	- Current (inrush) (a.c. A, peak and duration)		N/A
	- Frequency (nominal or range) (Hz)		N/A
	d.c input (other than PV) quantities:		N/A
	- Voltage (nominal or range) (d.c. V)		N/A
	- Nominal battery voltage (d.c. V)		N/A
	- Current (maximum continuous) (d.c. A)		N/A
	d.c. output quantities:		N/A
	- Voltage (nominal or range) (d.c. V)		N/A
	- Nominal battery voltage (d.c. V)		N/A
	- Current (maximum continuous) (d.c. A)		N/A
	Protective class (I or II or III)		P
	Ingress protection (IP) rating per part 1		P
5.3.2.2	Grid-interactive inverter setpoints		N/A
	For a grid-interactive unit with field adjustable trip points, trip times, or reconnect times, the presence of such controls, the means for adjustment, the factory default values, and the limits of the ranges of adjustability shall be provided in the documentation for the PCE or in other format such as on a website. Provided solution: .....	Not with field adjustable trip points	N/A
	The setting of field adjustable setpoints shall be accessible from the PCE		N/A
5.3.2.3	Transformers and isolation		N/A
	whether an internal isolation transformer is provided, and if so, what level of insulation (functional, basic, reinforced, or double) is provided by that transformer. The instructions shall also indicate what the resulting installation requirements are regarding such things as earthing or not earthing the array, providing external residual current detection devices, etc.		N/A
	An inverter shall be provided with information to the installer regarding:		-
	- providing of internal isolation transformer		N/A
	- the level of insulation (functional, basic, reinforced, or double)		N/A
	The instructions shall also indicate what the resulting installation requirements are regarding:		-
	- earthing or not earthing the array		N/A

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
	- providing external residual current detection devices		N/A
	- requiring an external isolation transformer,		N/A
5.3.2.4	Transformers required but not provided		N/A
	An inverter that requires an external isolation transformer not provided with the unit, shall be provided with instructions that specify, and for the external isolation transformer with which it is intended to be used:		-
	- the configuration type		N/A
	- electrical ratings		N/A
	- environmental ratings		N/A
5.3.2.5	PV modules for non-isolated inverters		P
	Non-isolated inverters shall be provided with installation instructions that require PV modules that have an IEC 61730 Class A rating		P
	If the maximum AC mains operating voltage is higher than the PV array maximum system voltage then the instructions shall require PV modules that have a maximum system voltage rating based upon the AC mains voltage.		P
5.3.2.6	Non-sinusoidal output waveform information		N/A
	The instruction manual for a stand-alone inverter not complying with 4.7.5.2 shall include a warning that:		-
	- the waveform is not sinusoidal,		N/A
	- some loads may experience increased heating,		N/A
	- the user should consult the manufacturers of the intended load equipment before operating that load with the inverter		N/A
	The inverter manufacturer shall provide information regarding:		-
	- what types of loads may experience increased heating		N/A
	- recommendations for maximum operating times with such loads		N/A
	The inverter manufacturer shall specify for the waveforms as determined by the testing in 4.7.5.3.2 through 4.7.5.3.4.:		-
	- THD		N/A
	- slope		N/A
	- peak voltage		N/A
5.3.2.7	Systems located in closed electrical operating areas		
	Where required by 4.8.3.6, an inverter not provided with full protection against shock hazard on the PV array shall be provided with installation instructions:		-

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
	- requiring that the inverter and the array must be installed in closed electrical operating areas		N/A
	- indicating which forms of shock hazard protection are and are not provided integral to the inverter (for example the RCD, isolation transformer complying with the 30 mA touch current limit, or residual current monitoring for sudden changes)		N/A
5.3.2.8	Stand-alone inverter output circuit bonding		N/A
	Where required by 7.3.10, the documentation for an inverter shall include the following:		-
	- if output circuit bonding is required but is not provided integral to the inverter, the required means shall be described in the installation instructions, including which conductor is to be bonded and the required current carrying capability or cross-section of the bonding means;		N/A
	- if the output circuit is intended to be floating, the documentation for the inverter shall indicate that the output is floating.		N/A
5.3.2.9	Protection by application of RCD's	Integrated RCM used inside	N/A
	Where the requirement for additional protection in 4.8.3.1 is met by requiring an RCD that is not provided integral to the inverter, as allowed by 4.8.3.4, the installation instructions shall state the need for the RCD,.		N/A
	and shall specify its rating, type, and required circuit location		N/A
5.3.2.10	Remote indication of faults		N/A
	The installation instructions shall include an explanation of how to properly make connections to (where applicable), and use, the electrical or electronic fault indication required by 13.9.		N/A
5.3.2.11	External array insulation resistance measurement and response	Integrated resistance measurement inside	N/A
	The installation instructions for an inverter for use with ungrounded arrays that does not incorporate all the aspects of the insulation resistance measurement and response requirements in 4.8.2.1, must include:		-
	- for isolated inverters: an explanation of what aspects of array insulation resistance measurement and response are not provided, and		N/A



IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
	- an instruction to consult local regulations to determine if any additional functions are required or not;		N/A
	- for non-isolated inverters: an explanation of what external equipment must be provided in the system, and		N/A
	- what the setpoints and response implemented by that equipment must be, and:		N/A
	- how that equipment is to be interfaced with the rest of the system.		N/A
5.3.2.12	Array functional grounding information		N/A
	Where approach a) of 4.8.2.2 is used, the installation instructions for the inverter shall include all of the following:		-
	a) the value of the total resistance between the PV circuit and ground integral to the inverter .....		N/A
	b) the minimum array insulation resistance to ground that system designer or installer must meet when selecting the PV panel and system design, based on the minimum value that the design of the PV functional grounding in the inverter was based on .....		N/A
	c) the minimum value of the total resistance $R = V_{MAX} PV/30 \text{ mA}$ that the system must meet, with an explanation of how to calculate the total .....		N/A
	d) a warning that there is a risk of shock hazard if the total minimum resistance requirement is not met.		N/A
5.3.2.13	Stand-alone inverters for dedicated loads		P
	Where the approach of 4.7.5.5 is used, the installation instructions for the inverter shall include a warning that the inverter is only to be used with the dedicated load for which it was evaluated, and		P
	shall specify the dedicated load.		N/A
5.3.2.14	Identification of firmware version(s)		N/A
	An inverter utilizing firmware for any protective functions shall provide means to identify the firmware version.		N/A
	This can be a marking, but the information can also be provided by a display panel, communications port or any other type of user interface.....		N/A

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
7	PROTECTION AGAINST ELECTRIC SHOCK AND ENERGY HAZARDS		P
7.3	Protection against electric shock		P
7.3.10	Additional requirements for stand-alone inverters		P
	One circuit conductor bonded to earth to create a grounded conductor and an earthed system.		P
	The means used to bond the grounded conductor to protective earth provided within the inverter or as part of the installation	External earthing needed	P
	If not provided integral to the inverter, the required means shall be described in the installation instructions as per 5.3.2.8.		N/A
	The means used to bond the grounded conductor to protective earth shall comply with the requirements for protective bonding in Part 1,		P
	If the bond can only ever carry fault currents in stand-alone mode, the maximum current for the bond is determined by the inverter maximum output fault current.		N/A
	Output circuit bonding arrangements shall ensure that in any mode of operation, the system only has the grounded circuit conductor bonded to earth in one place at a time..		N/A
	Switching arrangements may be used, in which case the switching device used is to be subjected to the bond impedance test along with the rest of the bonding path		N/A
	Inverters intended to have a circuit conductor bonded to earth shall not impose any normal current on the bond except for leakage current.		N/A
	Outputs that are intentionally floating with no circuit conductor bonded to ground, must not have any voltages with respect to ground that are a shock hazard in accordance with Clause 7 of Parts 1 and 2.		P
	The documentation for the inverter shall indicate that the output is floating as per 5.3.2.8.		P
7.3.11	Functionally grounded arrays		N/A
	All PV conductors in a functionally grounded array shall be treated as being live parts with respect to protection against electric shock.		N/A

IEC 62109-2			
Clause	Requirement – Test	Result – Remark	Verdict
<b>9</b>	<b>PROTECTION AGAINST FIRE HAZARDS</b>		-
9.3	Short-circuit and overcurrent protection		-
9.3.4	Inverter backfeed current onto the array		-
	The backfeed current testing and documentation requirements in Part 1 apply, including but not limited to the following.		P
	Inverter backfeed current onto the PV array maximum value.....	0mA	P
	This inverter backfeed current value shall be provided in the installation instructions regardless of the value of the current, in accordance with Table 33.		P
<b>13</b>	<b>PHYSICAL REQUIREMENTS</b>		-
13.9	Fault indication		-
	Where this Part 2 requires the inverter to indicate a fault, both of the following shall be provided:		-
	a) a visible or audible indication, integral to the inverter, and detectable from outside the inverter, and		P
	b) an electrical or electronic indication that can be remotely accessed and used.		P
	The installation instructions shall include information regarding how to properly make connections (where applicable) and use the electrical or electronic means in b) above, in accordance with 5.3.2.10.	Refer to installation instructions	P

4.4.4	TABLE: Single fault condition to be applied					P
	Ambient temperature (°C) .....	25				—
	Power source for EUT: Manufacturer, model/type, output rating .....	--				—
4.4.4.15.1	Fault-tolerance of residual current monitoring					
Component No.	Fault	Supply voltage (V)	Test time	Fuse #	Fuse current (A)	Observation
Residual current monitoring	Drive circuit o-c	800	10s	--	--	PV inverters disconnect from grid immediately and shut down. No hazard.
Residual current monitoring	Drive circuit s-c	800	10s	--	--	PV inverters disconnect from grid immediately and shut down. No hazard.
Check that the residual current monitoring operates properly						Yes
Supplementary information:						

4.4.4	TABLE: Single fault condition to be applied					P
	Ambient temperature (°C) .....		25			—
	Power source for EUT: Manufacturer, model/type, output rating .....		--			—
4.4.4.15.2	Fault-tolerance of automatic disconnecting means					
Component No.	Fault	Supply voltage (V)	Test time	Fuse #	Fuse current (A)	Observation
Relay function checking	Drive circuit o-c	800	10s	--	--	PV inverters cannot work. No hazard.
Relay function checking	Drive circuit s-c	800	10s	--	--	PV inverters cannot work. No hazard.
Check that the relays fulfil the basic insulation or simple separation based on the PV circuit working voltage.						Relays fulfil the basic insulation or simple separation.
Each active phase can be switched. (L and N)						All pole disconnection.
Legend						
FID	Fault Indication			MT	Max. Temperature	
SD	PCE Shut Down:			DG	Disconnection To Grid	
RO	Recovered to Operate after removing the single fault setting			NCD	No Comp. or parts Damaged	
NH	No Hazards occurred			PEST	Pass the Electric Strength Test.	
s-c	short-circuited			o-c	open-circuited	
o-l	over-load.					
Supplementary information:						
The electric strength test performed after fault condition test and see appended table 7.5.2 of Part1 for detailed test conditions.						

<b>4.4.4.17</b>	<b>Cooling system failure – Blanketing test</b>		<b>P</b>
	Test voltage (Vdc).....:	850.0	—
	Test current (Idc)	72.682	—
	Test voltage (Vac).....:	230.06	—
	Test current (Iac)	86.756	—
	t <sub>amb1</sub> (°C) .....	40.3	—
	t <sub>amb2</sub> (°C) .....	40.2	—
maximum temperature T of part/at:		T (°C)	T <sub>max</sub> (°C)
1.	Enclosure(side)	65.4	70
2.	Heatsink	66.7	70
3.	Enclosure(Top)	65.2	70
Supplementary information:			

<b>4.7.4</b>	<b>TABLE: Steady state Inverter AC output voltage and frequency</b>		<b>N/A</b>
	Nominal DC input (V)		
	Nominal output AC voltage (V)		
AC output U (V)	Frequency (Hz)	Condition/status	Comments
Supplementary information:			

4.8.2	TABLE: Array insulation resistance detection for inverters for ungrounded and functionally grounded arrays				P
4.8.2.1	Array insulation resistance detection for inverters for ungrounded arrays				P
DC Voltage below minimum operating voltage(V)	DC Voltage for inverter begin operation(V)	Resistance between ground and PV input terminal (kΩ)	Required Insulation resistance R = (V <sub>MAX PV</sub> / 30mA) (kΩ)	Result	
DC+					
190 V	210V	32kohm	33.3kohm	the unit cannot start operation until the insulation resistance has recovered	
190 V	210V	35kohm	33.3kohm		
DC-					
190 V	210V	32kohm	33.3kohm	the unit cannot start operation until the insulation resistance has recovered	
190 V	210V	35kohm	33.3kohm		
Note:					
For isolated inverters, shall indicate a fault in accordance with 13.9 (operation is allowed); the fault indication shall be maintained until the array insulation resistance has recovered to a value higher than the limit above					
For non-isolated inverters, or inverters with isolation not complying with the leakage current limits in the minimum inverter isolation requirements in Table 30, shall indicate a fault in accordance with 13.9, and shall not connect to the mains; the inverter may continue to make the measurement, may stop indicating a fault and may connect to the mains if the array insulation resistance has recovered to a value higher than the limit above.					
It is not required to test all PV input terminals if analysis of the design indicates that one or more terminals can be expected to have the same result, for example where multiple PV string inputs are in parallel.					
Supplementary information:					

4.8.3.2	TABLE: 30mA touch current type test for isolated inverters		N/A
Condition		Current (mA)	Limit (30mA)
--		--	--
--		--	--
Supplementary information: Non-isolated type inverter.			

4.8.3.3	TABLE: Fire hazard residual current type test for isolated inverters			N/A
Condition		Current (mA)	Limit (300mA or 10mA per kVA)	
--		--	--	
--		--	--	
Supplementary information: Non-isolated type inverter.				



4.8.3.5	TABLE: Protection by residual current monitoring			P
Test conditions:		Output power (kVA): 60 Input voltage (V <sub>DC</sub> ): 850 Frequency (Hz):50Hz Output AC Voltage ( V <sub>AC</sub> ): 230Vac		
4.8.3.5.2	Test for detection of excessive continuous residual current			P
Fault Current (mA)		Disconnection time (ms)		
Measured Fault Current	Limit 300mA for output power ≤ 30 kVA 10mA per kVA for output power > 30 kVA	Measured Disconnection time	Limit	
+ PV to N:				
287.4	600	138.0	300	
287.4	600	152.0	300	
287.4	600	162.0	300	
287.4	600	186.0	300	
298.9	600	158.0	300	
- PV to N:				
287.4	600	144.0	300	
287.4	600	160.0	300	
287.4	600	162.0	300	
298.9	600	150.0	300	
298.9	600	190.0	300	
Note: – maximum 300mA for inverters with continuous output power rating ≤30 kVA; – maximum 10mA per kVA of rated continuous output power for inverters with continuous output power rating > 30 kVA.  This test shall be repeated 5 times, and for all 5 tests the time to disconnect shall not exceed 0,3s. The test is repeated for each PV input terminal. It is not required to test all PV input terminals if analysis of the design indicates that one or more terminals can be expected to have the same result, for example where multiple PV string inputs are in parallel.				
Supplementary information: 100% output power and Vmppmax input voltage				

4.8.3.5.3	TABLE: Test for detection of sudden changes in residual current		P
+PV to N			
Limit (mA)	U <sub>N</sub>		Limit (ms)
	Disconnection time (ms)		
30	145.0		300

30	127.0	300
30	110.0	300
30	118.0	300
30	132.0	300
60	55.0	150
60	80.0	150
60	56.0	150
60	57.6	150
60	56.4	150
150	11.0	40
150	14.2	40
150	14.1	40
150	14.6	40
150	16.2	40
-PV to N		
Limit (mA)	U <sub>N</sub>	Limit (ms)
	Disconnection time (ms)	
30	158.0	300
30	146.0	300
30	148.0	300
30	174.0	300
30	214.0	300
60	71.0	150
60	88.0	150
60	109.0	150
60	90.0	150
60	80.0	150
150	36.8	40
150	38.0	40
150	28.4	40
150	30.4	40
150	28.8	40
Note:		
The capacitive current is raised until disconnection.		
Test condition: $I_c + 30/60/150\text{mA} \leq I_{c\text{max}}$ . R <sub>1</sub> is set that 30/60/150mA Flow and switch S is closed.		
Supplementary information: 100% output power and Vmppmax input voltage		

Test Equipment list				
No	Test Equipment	Equipment model	Equipment No.	Calibration due date
1	Simulation of ac power supply	WPLA-330200KVA	BZ-DGD-L204	2022/12/22
2	Solar IV simulator	WLPA-150KW	BZ-DGD-L013	2022/12/22
3	Oscilloscope	MS04054B	BZ-DGD-L064	2023/02/28
4	DC power supply	IT6861A	BZ-DGD-L233	2022/11/02
5	Scribing rheostat	BX8D	BZ-DGD-L098	--

## Statement

1. The laboratory guarantees the scientificity, accuracy and impartiality of the test, and is responsible for all the information in the report, except the information provided by the customer. The customer is responsible for the impact of the information provided on the validity of the results.
2. The report without China inspection body and laboratory Mandatory Approval (CMA) mark has no effect of proving to the society.
3. For the report with CNAS mark, the items marked with "☆" are not within the accredited scope.
4. This report is invalid if it is altered, without the signature of the testing and approval personnel, or without the "inspection and testing dedicated stamp" or test report stamp.
5. The test data and results are only valid for the tested samples provided by the customer.
6. This report shall not be partially reproduced without the written permission of the laboratory.
7. Any objection shall be raised to the laboratory within 30 days after receiving the report.

**--- End of report---**